



NOTES:

1. For pipe sizes of ten (10) inches in diameter and larger a manhole is to be installed. Refer to East Valley Water District Standard Drawing S-104 for manhole construction.
2. For pipe sizes of six (6) inches to eight (8) inches in diameter a cleanout is to be installed at dead ends.

DEAD END - PIPE CLEANOUT

M:\Engineering - Secured\Standards\DWG\2022 Update\Sewer



EAST VALLEY WATER DISTRICT, ENGINEERING DEPARTMENT

APPROVED BY:

Jeff Noelte

JEFF NOELTE, P.E. 67924
DIRECTOR of ENGINEERING and OPERATIONS

APRIL 2022
REVISION

**EVWD
STD. DWG.
S-107**

SHEET 1 OF 1